


2025-001
ADDENDUM 1



**PUBLIC UTILITY DISTRICT NO. 1
OF FERRY COUNTY**

2025-001

Addendum 1

ATTENTION:

This Addendum 1 consists of a total of 2 pages, including this page.

All bidders are hereby notified that the bid documents for the subject project have been amended as hereinafter set forth. The following changes, additions, and/or deletions are hereby made part of the bid documents.

1. Nominal Transformer Voltages

- a. The 15/20/25 MVA Three Phase Power Transformer shall have a high side voltage of 34,400 V Delta and a low side voltage of 12,470 V Wye.

2. Acceptance of dry out methods

- a. Alternate dry out methods **will be accepted:** Under the following requirements:
 - i. Insulation moisture content is less than 0.5%.
 - ii. If the transformer is shipped full of oil before the final fill the transformer has to be filled with dry air or nitrogen for 48 hours before the dew point measurement.
 - iii. If the transformer is shipped without oil before shipment after it is drained after the factory acceptance test. The transformer has to be filled with dry air for 24 hours before the dew point measurement. In this case the transformer cannot be opened after the dew point measurement.
- b. For the dew point measurement, the following must be provided:
 - i. Dew point reading.
 - ii. Insulation temperature.
 - iii. Pressure on the transformer.

2025-001
ADDENDUM 1

- iv. Insulation moisture content.
- 3. Shipping the transformer empty:
 - a. A dew point measurement of below 0.5% is acceptable.
- 4. POWER Engineers INC. is the administrative on this Call for Bids, the PUD is the requesting entity.
- 5. The Bid Proposal Form, and Transformer Proposal Form can be found in Section 4.

NOTE: Acknowledgement of the receipt of this addendum is required under “**2.2 s** and **2.4**” of the Call for Bids, Bid No. 2025-001 in order for the bid proposal to be considered complete. Failure to acknowledge receipt of this addendum may become cause for rejection of the bid.

Acknowledgement of Addendum 1

Bidder Business Name	
Bidder's Washington UBI No:	
OFFICIAL AUTHORIZED TO SIGN FOR BIDDER	
Print Name & Title:	
Signature:	Date: